

GOVERNMENT OF TRIPURA OFFICE OF THE SUB-DIVISIONAL OFFICER INTERNAL ELECTRIFICATION SUB-DIVISION NO-I GURKHABASTI AGARTALA

No.BLD-03/AE/IESD-I/2022-23/ 561-63

Date: 05/08/ 2022

To

The Principal-in-charge

Sachin Debbarman Memorial

Government Music College

Lichubagan, Agartala, Tripura (West)

Subject: Energy Audit in the campus of S.D.B.M. Govt. Music College, Lichubagan, Agartala

Ref No: (i) Your office letter No.F.2 (26) SDBMGMC/Estt./2022/141(5) Dated-28/07/2022.

Sir,

In response to the above subject, it is intimated here that connected load of S.D.B.M. Govt. Music College, Lichubagan, Agartala is 33.60 KW (approx.). Necessary load of the different electrical points are also enclosed herewith.

This is for favour of your kind information.

Enclo: As stated

Yours faithfully

Sub-Divisional Officer (Elect)

Internal Electrification Sub-Division No-I

Agartala, Tripura (West)

Copy to:-

- The Executive Engineer, Internal Electrification Division, Agartala for favour of his kind information & necessary action please.
- 2. Er. Biplob Das, Junior Engineer of this office for information. This is as per physical verification made on 01/08/2022.

Sub-Divisional Officer (Elect)
Internal Electrification Sub-Division No-I
Agartala, Tripura (West)

			Load Ce	rtificate			To the to
Name	of work: Total con	nected load	in the ca	mpus of S.D	.B.M. Govt.	Music Coll	ege,
		Det	ail of elec	ctrical Load			
SI no	Fittings	No of point				watt	Total Watt
	-	Ground Floor	First Floor	Second Floor	Total		
1	Ceiling fan	49	57	30	136	60	8160
2	Tube light	90	87	90	267	40	10680
3	Angle Holder	11	6	8	25	9	225
4	2x9 w CFLFittings	10	20	22	52	18	936
5	Exhaust Fan	6	6	4	16	10	160
6	AC (1.5 ton)			2	2	1800	3600
7	Outdoor LED			5	5	60	300
8	5 amps socket	10	20	20	50	100	5000
9	15 amps socket	1	1	1	3	1000	3000
10	2 h.p motor			2	2	750	1500
						Total	33561
	Say 33.6 KW(Apr						(W(Aprro

Er. BIPLAB DAS (J.E.)
I. E. Sub-Division No.-I
Gurkhabasti, Agartala.

S D.O. (Elect)
IE Sub-Division-I,
Gurkhabasti, Agartala